

## Technical Specification 021.01

### LOW PRESSURE SEWER SYSTEMS AND GRINDER PUMPS

#### 1.0 General

- a) Gravity sewer systems are the preferred alternative for service to Brunswick County residential and commercial customers. Some situations require the use of alternative sewer systems such as vacuum systems or low pressure sewer systems utilizing grinder pumps.
- b) It is the intent of this specification to provide technical guidance and information concerning the design and installation of low pressure sewer systems with grinder pumps that are permitted and installed in Brunswick County's Public Utilities' service area.
- c) The design engineer should be familiar with all NCDENR / DWQ rules and minimum design criteria for low pressure sewer systems with grinder pumps.
- d) Refer to the design section -- Part F -- of this Design Manual for detailed design guidance for low pressure sewer systems utilizing grinder pumps.

#### 2.0 Low Pressure Sewer System Main and Service Lateral Materials

- a) Low pressure sewer system mains shall be:
  - 1) PVC pipe manufactured in accordance with ASTM D1785, ASTM D2241, ASTM D2672, or AWWA C900 as follows:
    - Pipes (2) – (4) inches diameter: minimum SDR-21
    - Pipes larger than (4) inch diameter: minimum DR-18
    - Pipes less than (2) inch diameter: SDR-21 and /or Schedule 40 PVC
    - All force main piping installed in NCDOT rights-of-way shall be minimum DR-18
  - 2) DIP manufactured in accordance with AWWA C151 and C150 with pressure class 350.
  - 3) HDPE pipe manufactured in accordance with ASTM D2239, D3035, or AWWA C901.
  - 4) Fusible PVC pipe manufactured in accordance with AWWA C900 or AWWA C905 with ASTM cell classification 12454.
  - 5) ABS pressure pipe is prohibited for low pressure sewer systems in Brunswick County.

- b) All low pressure sewer pipes shall be marked with diameter, manufacturer's name or trademark, pressure pipe type, grade and class, and shall be clearly visible for inspection purposes.
- c) All piping shall be installed in accordance with force main piping requirements per Brunswick County's Technical Specification TS 022.01: Waste Water Force Mains and all NCDENR / DWQ guidance document requirements.
- d) The sewer mains shall be located, to the maximum extent possible, in areas where damage is less likely and disruption to the neighborhood is minimized.
- e) Low pressure sewer system mains installation and testing:
  - 1) Install low pressure sewer pipe with a minimum cover depth of (36) inches for all non-ferrous pipe. Limit trench widths to disturb as little undisturbed soil as possible. Trench backfill beneath pavement should be compacted in (9) inch lifts.
  - 2) Provide thrust restraint as required at all bends greater than (22.5) degrees and all tees, wyes, stops, valves or changes in pipe size, or per approved plans. Concrete thrust blocking and restrained joints are acceptable forms of thrust restraint. Refer to County Standard Details.
  - 3) Prior to commencement of pressure and leakage tests, all piping shall be pigged or flushed at minimum of (2.5) feet per second velocity to result in at least a 100% turnover of the water in the pipeline.
  - 4) All piping shall be tested to (150) percent of the maximum operating pressure – (100) psig minimum - for a period of time not less than (2) hours and shall be witnessed by the Engineer and / or County staff.
  - 5) For water main crossings refer to Brunswick County's Water and Sewer Crossings Standard Details and comply with all DENR / PWSS / DWQ rules on water and sewer main crossings.
- f) Low pressure sewer service laterals shall be:
  - 1) (1.5) inch for residential, or (2.0) inch for commercial, AWWA C901, SDR- 9, polyethylene (PE) CTS, with a minimum pressure rating of (200) psi.
  - 2) Service taps and laterals shall consist of the tapping saddle and valve, service line tubing, and the service box containing an isolation plug valve and a check valve. No joints are permitted in the service tubing between the main line tapping saddle and the service box at the right-of-way or easement line. The service box isolation plug valve shall be installed between the main and the check valve to allow the main pressure to be isolated for check valve replacement.
  - 3) The lid of the service box shall be marked SEWER with the lid painted green.

- 4) Refer to the County Low Pressure Sewer System Standard Detail for additional information.
- g) Push on joints shall be:
  - 1) A single elastomeric gasket type with a pressure rating not less than the pipe pressure rating and meeting the performance requirements of ASTM D3139.
- h) Restrained joints (RJ) shall be:
  - 1) Required where indicated on the approved drawings.
  - 2) DIP: the restrained joint system shall have a pressure rating equal to or greater than that of the pipe on which it is used; push – on type joints shall be a standard manufacturer’s RJ system such as Snap-Lock (Griffin Pipe), T R Flex (U.S. Pipe), Clow Super Lock, or approved equal; mechanical type joints shall be Meg-A-Lug (EBAA Iron), Cam-Lock, Sigma Corporation, or approved equal.
  - 3) PVC: the restrained joint system shall have a pressure rating equal to or greater than that of the pipe on which it is used; push – on type joints shall be a standard manufacturer’s RJ system such as Snap-Lock (Griffin Pipe), T R Flex (U.S. Pipe), Clow Super Lock, or approved equal; mechanical type joints shall be Meg-A-Lug (EBAA Iron), Cam-Lock, Sigma Corporation, or approved equal.
  - 4) All retainer gland type RJ shall be Meg-A-Lug (EBAA Iron), Cam-Lock, Sigma Corporation, or approved equal.
  - 5) PVC and/or DIP to IPS pipe: deep bell, ductile iron, with knuckle restraint, as manufactured by Sigma, HARCO, or approved equal.
- i) Vent pipe (if required for floodplain applications) shall be:
  - 1) (2) inch, Schedule 80 PVC, vented through the side wall of the grinder tank, and shall replace the standard top mounted mushroom vent, and the vent pipe opening shall be screened and terminate a minimum of (2) feet above the (100) year flood elevation or as directed by the Engineer.
- j) Fittings shall be:
  - 1) Fittings for PVC pipe three (3) inch and smaller: deep bell, ductile iron, with knuckle restraint, as manufactured by Sigma, HARCO, or approved equal. Glue joint fittings are also acceptable for PVC pipe three (3) inches and smaller.
  - 2) Fittings for PVC pipe four (4) and larger: AWWA C115, interior shall have either a cement lining, a Protecto 401 lining, or approved equal, with the exterior coated with coal tar epoxy or other bituminous coating to

resist ground corrosion, as manufactured by Sigma, HARCO, or approved equal.

k) Air Release Facilities:

- 1) Air release facilities shall be similar to that specified in the Brunswick County Technical Specification TS 022.01: Waste Water Force Mains. Air release facilities shall be located at summits of all pressure sewer systems and properly sized to prevent buildup of air or gases. All air releases shall be automatic type.
- 2) Manual air releases are not permitted. Comply with all NCDENR / DWQ rules on locations of air release valves.
- 3) Boxes and vaults for air release facilities, cleanouts and other appurtenances shall be sized to permit easy removal of the facilities and permit operations of the valves. "Sewer" shall be clearly marked on the box or vault cover. Refer to County Standard Details.

l) Locating wire and marker balls:

- 1) All low pressure sewer main piping shall have a #12 AWG, high strength copper clad steel conductor (HS-CCS) such as Copperhead Superflex, or approved equal, with HDPE insulation, and rated for direct burial. Listed and approved underground connectors shall be used for all splices. The wire shall be brought up into a valve box at (1,000) feet maximum intervals to provide wire access points. The wire shall be taped to the top of the force main at minimum ten (10) foot intervals.

The contractor shall be required to perform a signal strength test of the installed tracer wire at the end of the installation with County staff present.

- 2) In addition to the tracing wire, electronic marker balls may be required on the force main. Refer to Brunswick County Technical Specification TS 035.01: Electronic Markers for Water and Sewer Pressure Mains for technical and installation requirements.

m) Low pressure connection to existing County sewer system:

- 1) All low pressure connections to gravity sewer systems shall be made at a manhole and enter at the existing invert to minimize turbulence of flow and the release of hydrogen sulfide gas. If the force main cannot enter at the existing invert then an inside drop must be constructed per County Standard Details.
- 2) The manhole must be coated on the interior per County specifications to protect against hydrogen sulfide gas. A carbon filter must be provided on any manhole that has a low pressure sewer system connection.

- n) In-line cleanouts and shutoff valves:
  - 1) In-line cleanouts and shutoff valves shall be provided on low pressure sewer main lines.
  - 2) Spacing of cleanouts and shutoff valves shall not be less than (600) feet of main line in high density areas and not less than (1,000) feet in low density areas.
  - 3) Cleanouts shall be provided on the upstream side of all directional drills with a vertical elevation change of ten (10) feet or greater.
  - 4) In-line isolation valves are required of both sides of all directional drills.

### 3.0 Packaged Grinder Pump Systems

- a) Simplex residential packaged low pressure sewer grinder pumps shall be:
  - 1) Barnes OGP, or approved equal
- b) Commercial and Industrial duplex pump stations shall be permitted in the owner's name and shall be operated and maintained by the owner. The design engineer shall model the system and select a pump with the appropriate discharge head conditions to operate satisfactorily under all operating conditions. Contact County Engineering for assistance with system modeling information and sewer system pressure data.

**Brunswick County Public Utilities prefers the Barnes OGP for the non-residential duplex pump applications.**

- c) Packaged System Requirements

- 1) Wetwell:

Fiberglas, minimum storage of (360) gallons above the PUMP OFF level, (4) inch dia. PVC inlet flange for Schedule 40 PVC sanitary line, pump discharge brass adapter socket, easily adaptable to either (1.5) inch for residential, or (2) inch for commercial applications, PVC or HDPE pipe materials, aluminum lid, mushroom vent on tank lid, extended base, integral to the tank, for anchoring the anti-flotation concrete ballast to tank, contractor shall provide concrete ballast as required, wet well shall not be installed in the rear of the house or inside any fenced area, removal of pumps and / or operation of discharge valve shall not require personnel entry into the tank.

For floodplain applications: watertight lid, solid, no mushroom vent on lid, (2) inch NPT female hub shall be provided in place of the mushroom vent for installation by the Contractor for side wall venting of the tank utilizing Schedule 80 PVC vent piping.

## 2) Pump and motor:

Vertical rotor, motor driven, solids handling type, double o-ring seal at all casting joints, pump castings cast iron, fully epoxy coated 8-10 mils nominal dry thickness, rotor shall be stainless steel, through-hardened, polished, maximum discharge pressure shall not exceed 150 psi, minimum 1.0 HP with 2.0 HP standard.

## 3) Electrical:

240 VAC, 60 Hz, single phase, 3450 RPM, pump cord length (15) feet minimum, UL and CSA listed, quick connect cord for watertight attachment to pump.

## 4) Grinder:

Mounted directly below the pumping elements, direct-driven, fastened to the pump motor shaft by means of a threaded connection only, cutter teeth hardened to Rockwell 50-60 for abrasion resistance, solids must be fed in an upward flow direction.

## 5) Integral Check Valve:

Factory installed, gravity operated, flapper type integral check valve built into the stainless steel discharge piping, must provide a full-ported passageway when open, working parts constructed of 300 series stainless steel and fabric reinforced synthetic elastomer to ensure corrosion resistance.

## 6) Level Controls:

Starting controls to be located in the cast iron enclosure of the core unit – plastic enclosure for starting controls is not acceptable, provide float switch type level controls for PUMP OFF, PUMP ON, and HIGH LEVEL ALARM in the wet well for simplex grinder pump stations, provide float switch type level controls for PUMPS OFF, LEAD PUMP ON, LAG PUMP ON, and HIGH LEVEL ALARM for duplex grinder pump stations, pump on / off and high level alarm functions shall not be controlled by the same switch.

Float switches shall consist of a mercury tube switch sealed within a corrosion resistant polypropylene housing with a minimum (18) gauge, (2) wires, SJOW / A jacketed cable. The cable shall be of sufficient length to reach the connection junction box without splicing. The floats shall be suspended from a stainless steel support bracket mounted inside the wet well such that any adjustment or replacement may be done without entering the tank. Float level controls shall be UL / CSA listed and approved.

## 7) Power and Control Cables:

The power and control cables shall be a minimum of (25) feet long or as needed to connect the wet well to the pump control panel. The power and control cables shall not be spliced between the wet well and pump control panel. The cables shall be UL / CSA listed and approved. The power and control cables shall be installed in minimum (1.5) inch PVC conduit (simplex pump) and minimum (2.0) inch PVC conduit (duplex pumps).

The conduit ends shall be sealed at each end with non-hardening duct sealant. At the discretion of Brunswick County Public Utilities a direct burial rated power and control cable assembly may be utilized. Any direct burial cable assembly shall be UL / CSA listed and approved.

Connection of power and control cables at the wet well shall be a sealed watertight connection. Power cable shall be sealed at the motor and clamped in place with a rubber watertight seal bushing to seal the outer jacket against leakage and to provide for strain relief. Cables shall withstand a pull of 300 pound force.

## 8) Control Panel:

Automatic control panel, NEMA 4X rated, UV resistant, UL listed for wall or pole mounting, hinged, lockable cover, high level alarm with red lexan (polycarbonate) alarm light and alarm horn, must be mounted so the alarm light is visible from the street, control panel must be within line-of-sight of the wet well, a placard must be affixed to the control panel with the emergency Brunswick County Public Utilities phone number on the placard for the owner's use in an emergency situation.

All internal wiring to be neat and color coded. A schematic wiring diagram shall be permanently affixed to the inside of the panel door. An installation and service manual for each control panel shall be provided Brunswick County Public Utilities.

## 9) Local Disconnects:

Simplex Pump local disconnect: a 220 VAC, double pole, (30) ampere rated electrical disconnect is required adjacent to the grinder pump control panel. Disconnect to be UL listed and rated for outdoor applications and installed per all NEC and Authority Having Jurisdiction (AHJ) requirements.

This disconnect is required on the homeowner's branch circuit supplying the grinder pump panel and shall be installed before Brunswick County will energize the grinder pump system.

Duplex Pump local disconnect: A local electrical disconnect adjacent to the duplex pump control panel is required. The contractor is responsible for properly sizing and installing the disconnect per all NEC and Authority

Having Jurisdiction (AHJ) requirements. Disconnect to be UL listed and rated for outdoor applications.

This disconnect is required on the branch circuit supplying the duplex grinder pump panel and shall be installed before Brunswick County will energize the grinder pump system.

10) Warranty:

Minimum (2) year parts and labor warranty on the complete station and accessories, including, but not limited to, the control panel, pump and motor assembly, and integral check valve.