



County of Brunswick Water Quality Report–2007

DID YOU KNOW?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Distribution System

The Public Utilities Maintenance Department would like to let you know that we are here to serve you with any of your water needs 24 hours a day. If you plan to dig and are not sure who to call, we can help. We have all the numbers you will need to contact other utilities for locates. If you have any water quality issues or fill that your meter is not working, please contact our office at (910) 253-2860; we will be glad to work with you to solve any water issues. If you have questions about your backflow device or need it inspected, we can help -- please call (910) 253-2683.

Interesting Facts:

Total Brunswick County Water System Capacity: 30 MGD
The Greatest One Day System Demand of the Year for 2007 was 22.79 MGD, July 6th.

Contact Us...

Emergencies during business hours
(910) 253-2860

BILLING OFFICE (910) 253-2655
EMERGENCIES – After hours After 4 p.m. & Before 7:30 a.m.: 211 WTP – (910) 253-5797; Northwest WTP – (910) 371-3490

Last year, we conducted more than 500 tests for over 80 drinking water contaminants. This brochure is a snapshot of the quality of the water that we provided last year. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. For more information about your water, please call (910) 371-3490 and ask for Glenn Walker or Jeremy Sexton at (910) 253-5797.

Water Treatment Division

Our water comes from two sources, the Cape Fear River and groundwater from the Castle Hayne Aquifer. The Northwest Water Treatment Plant in Leland treats the water from the Cape Fear River. Our second source is utilized by the 211 Water Treatment Plant in Southport. Fourteen (14) different groundwater wells are tapped into the Castle Hayne Aquifer approximately 175 ft. below the ground's surface.

The NC Source Water Assessment Program (SWAP)

The North Carolina Department of Environment and Natural Resources (DENR), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate, or Lower.

The relative susceptibility rating of each source for Brunswick County was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings are summarized in the table below:

Susceptibility of Sources to Potential Contaminant Sources (PCSs)

Source Name	Susceptibility Rating
Cape Fear River	Moderate
Well # 1,2,3,5,6,8,11,12,12a,15,16,17,18, & 19	Moderate

The complete SWAP Assessment Report for the Brunswick County Water System may be viewed on the Web at: <<http://www.deh.enr.state.nc.us/pws/swap>>. To obtain a printed copy of this report please contact the Source Water Assessment staff by phone at (919) 715-2633. It is important to understand that a susceptibility rating of "higher" does not imply poor water quality, only the systems' potential to become contaminated by PCSs in the assessment area.

Northwest Water Treatment Plant

Northwest Water Treatment Plant attained 100% compliance (95% compliance is required by the state) for turbidity removal. As for in-house goals, plant staff kept turbidity levels below 0.10 ntu for 169 consecutive days and increased our yearly total to 359 days below 0.10 ntu. Congratulations Northwest Staff! One operator this year has reached a new certification level: Congratulations to Scott Wells for attaining his A-license in water treatment.



211 Water Treatment Plant

The 211 Water Treatment Plant Staff continues to provide quality water service to the areas of Southport, Oak Island, and St. James Plantation. Current projects are new wells scheduled for installation to boost plant capacity. Two operators have achieved new certification levels -- Congratulations to Miriam Watkins Jackowicz for attaining the B-license and to Richard Hewett for attaining the C-license for water treatment.



Terms & abbreviations used below:

- **Maximum Contaminant Level Goal (MCLG):** the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Action Level (AL):** the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **N/A:** not applicable • **nd:** not detectable at testing limit • **ppb:** parts per billion or micrograms per liter • **ppm:** parts per million or milligrams per liter • **pCi/l:** Pico-curies per liter (a measure of radiation)

Brunswick County Public Utilities Consumer Confidence Report Data

Water Quality Results For 2007

Listed below are the results of water quality sampling performed from January 1, 2007, to December 31, 2007.
 Questions and Comments: Glenn Walker, Water Treatment Plant Superintendent (910) 371-3490 or gwalker@brunsko.net

Substances	EPA's MCL	EPA's MCLG	Brunswick County Amount Detected	Range Low High	Violation Y/N	Source of Contaminant
Turbidity	Treatment Technique	N/A	Average 0.033ntu	Percent of samples below 0.3ntu	N	Soil Runoff
			Maximum 0.162 ntu	100.0%		
Raw Water TOC	Treatment Technique	N/A	7.5ppm	4.9 11.7	N	Naturally Present in the Environment
Finish Water TOC		N/A	3.9ppm	2.6 6.1		
Total Organic Carbon (TOC)	Treatment Technique	N/A	Removal Efficiency Average 45.9%	26.5% 67.5%		
INORGANIC CHEMICALS					Violation Y/N	
Chlorite	1.0ppm	0.8ppm	Average 0.66ppm	0.06 .99	N	By-product of Disinfection
Chlorine Dioxide	0.8ppm	0.8ppm	Average 0.01ppm	0.0 0.21	N	Water Additive Used to Control Microbes
Fluoride	4ppm	4ppm	Average 0.98ppm	0.19 1.21	N	Water Additive which Promotes Strong Teeth
Nitrate	10ppm	10ppm	1.08ppm	N/A	N	By-product of Disinfection
Sulfate	250ppm	N/A	23.8ppm	N/A	N	Part of the Treatment Process, Erosion of Natural Deposits
Orthophosphate			Average 2.51ppm	0.62 3.60	N	Water Additive Used to Control Corrosion
Substances	Action Level (AL)	MCLG	Brunswick County Amount Detected	# of Samples above the AL	Exceedence of the Action Level?	
Copper 90th percentile 1 4/18/07-5/01/07 2 9/11/07-11/30/07	1.3ppm	1.3ppm	0.082	0	N	Corrosion of Household Plumbing
			0.09	1	N	
Lead 90th percentile 1 4/18/07-5/01/07 2 9/11/07-11/30/07	0.015ppm	0ppm	0.012	2	N	Corrosion of Household Plumbing
			0.005	3	N	
ORGANIC CHEMICALS					Violation Y/N	
Chloramines	4ppm	4ppm	Average Minimum 2.52ppm	1.30 3.19	N	Water Additive Used to Control Microbes
Total Trihalomethanes	80ppb	N/A	Average 11.6ppb	1.0 34.0	N	By-product of Disinfection
Total Haloacetic Acids	60ppb	N/A	Average 14.5ppb	4.0 48.0	N	By-product of Disinfection
RADIONUCLIDES						
Beta 1/07/00	10 pCi/l	0	2.48 pCi/l		N	Erosion of Natural Deposits
UNREGULATED CONTAMINANTS						
Sodium	Non Regulated	N/A	48.9ppm		N/A	Part of the Treatment Process, Erosion of Natural Deposits
Bromoform	Non Regulated	N/A	1.3ppb		N/A	THM Component
BDChloromethane	Non Regulated	N/A	6.9ppb		N/A	THM Component
CDBromomethane	Non Regulated	N/A	8.1ppb		N/A	THM Component
Chloroform	Non Regulated	N/A	6.0ppb		N/A	THM Component

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Brunswick County Public Utilities is responsible for providing high-quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <<http://www.epa.gov/safewater/lead>>.



Brunswick County Water Quality Report 2007 Continued:

Our Utility Operations Board meets on the second Monday of each month at 5:30 p.m. in the Parks & Recreation/Mental Health Building. Please feel free to participate in these meetings.

Customer Tips

Citizens on HWY 211 who have County water service primarily receive water from the 211 WTP. Citizens from the Town of Northwest to Sunset Beach receive water from the Northwest WTP.

Water Quality & Conservation in the Home

Remove and flush faucet aerators regularly. This helps to keep debris such as pipe solder and sediment from clogging aerator screens, as well as provide the best quality water possible.

6 WAYS TO LOWER YOUR WATER BILL!


1. Wash only full loads of laundry.
2. Take a shower instead of a bath.

A 5- to 10-minute shower will save up to 45 gallons of water over taking a bath!

3. Turn off the faucet when brushing your teeth. Turning it off can save 8 gallons a day per person!
4. When replacing toilets, faucets, and shower heads, choose high-efficiency models. High efficiency toilets can save as much as 5 gallons of water per flush!

5. When purchasing appliances look for the Water Sense seal of approval. This is the Environmental Protection Agency's (EPA) drinking water conservation program to help ensure our water supply is available for future generations. For more information on this and other programs offered by the EPA please visit their website: <http://www.epa.gov/owm/water-efficiency/>
6. Purchase a rain sensor for your irrigation system so you don't water your landscaping during rain events. These little devices easily attach to most programmable sprinkler systems and can be purchased at most local home improvement stores.

Brunswick County
Water Plant Service Areas



WATER CONSERVATION NOTICE

All of Brunswick County is currently under a Stage 1 Water Conservation Alert. During a Stage 1 Water Conservation Alert, customers are asked to voluntarily conserve water.

REDUCE IRRIGATION FREQUENCY

For established lawns, daily irrigation is not required. Irrigate only when there is no moisture in the root zone.

IRRIGATE DURING OFF PEAK HOURS

Peak demand for water is between 6:00 AM to 10:00 a.m and 4:00 p.m. to 6:00 p.m. If irrigation is necessary, irrigate during off peak times.

CHECK FOR LEAKS AND REPAIR LEAKS IMMEDIATELY

Leaks such as running toilets and dripping faucets should be repaired immediately to reduce water consumption.

DO NOT WASH DOWN OUTSIDE AREAS SUCH AS DRIVEWAYS, SIDEWALKS, PATIOS, ETC.

USE HEAVY WATER-USING APPLIANCES DURING OFF PEAK HOURS

Appliances such as dishwashers and washing machines should be run during off peak times to reduce peak demand.