



Environmental Chemists, Inc.

6602 Windmill Way, Wilmington, NC 28405 • 910.392.0223 Lab • 910.392.4424 Fax
710 Bowsertown Road, Manteo, NC 27954 • 252.473.5702 Lab/Fax
255-A Wilmington Highway, Jacksonville, NC 28540 • 910.347.5843 Lab/Fax

ANALYTICAL & CONSULTING CHEMISTS

info@environmentalchemists.com

July 13, 2018

Brunswick County Public Utilities
Post Office Box 249
Bolivia, NC 28422
Attn: Glenn Walker

Report #2018-09494
Collected – June 14, 2018

Enclosed please find your analytical report.

Sincerely,

Tammy Duran
Environmental Chemists, Inc.

ANALYTICAL RESULTS: Perfluorinated Chemicals by EPA 537 Rev 1.1 Safe Drinking Water Analysis

Customer: Environmental Chemists NLS Project: 301918
 Project Description: EPA 537 with GenX
 Project Title: Template: 537PPT2GENX

Printed: 07/20/2018 11:02

Sample: 1062740_23910 (061418-E01) Collected: 06/14/18 Analyzed: 06/27/18 - Analytes: 13

ANALYTE NAME	RESULT	UNITS	WMB	DIL	LOD	LOQ	MCL	Note
perfluorobutanesulfonic acid (PFBS)	ND	ppt		1	3.6	11		
perfluorohexanoic acid (PFHxA)	14	ppt		1	0.83	2.6		
perfluoro-2-propoxypropanoic acid (GenX)	10.6	ppt		1	0.62	2.0		
perfluorohexanoic acid (PFHxA)	13.4	ppt		1	0.45	1.4		
perfluorohexanesulfonic acid (PFHxS)	[3.87]	ppt		1	1.3	4.1		J
perfluorooctanoic acid (PFOA)	8.29	ppt		1	0.70	2.2		
perfluorooctanoic acid (PFNA)	[1.82]	ppt		1	1.3	4.1		J
perfluorododecane sulfonic acid (PFOS)	11.3	ppt		1	1.5	4.7		
perfluorododecanoic acid (PFDA)	[2.09]	ppt		1	1.2	3.8		J
perfluoroundecanoic acid (PFUa)	ND	ppt		1	1.2	3.7		
perfluorododecanoic acid (PFDoA)	ND	ppt		1	0.95	3.0		
perfluorotridecanoic acid (PFTTDA)	ND	ppt		1	0.97	3.1		
perfluorotetradecanoic acid (PFTA)	ND	ppt		1	0.88	2.8		
C13-PFHxA (SURR)	77.843%			1				S
C13-PFDA (SURR)	87.265%			1				S

NOTES APPLICABLE TO THIS ANALYSIS:

J = Result enclosed in brackets is between LOD and LOQ, a region of less certain quantitation.
 S = This compound is a surrogate used to evaluate the quality control of a method.

ANALYTICAL RESULTS: Perfluorinated Chemicals by EPA 537 Rev 1.1 Safe Drinking Water Analysis

Customer: Environmental Chemists NLS Project: 301918

Project Description: EPA 537 with GenX

Project Title: Template: 537PPT2GENX Printed: 07/20/2018 11:02

Sample: 1062741 23911 (06/14/18-S01) Collected: 06/14/18 Analyzed: 06/27/18 Analytes: 13

ANALYTE NAME	RESULT	UNITS	WWB	DIL	LOD	LOQ	MCL	Note
perfluorobutanesulfonic acid (PFBS)	[3.68]	ppt		1	3.6	11		J
perfluorohexanoic acid (PFHxA)	12.8	ppt		1	0.83	2.6		
perfluoro-2-propoxypropanoic acid (GenX)	11	ppt		1	0.62	2.0		
perfluorohexanoic acid (PFHxA)	13.2	ppt		1	0.45	1.4		
perfluorohexanesulfonic acid (PFHxS)	[3.98]	ppt		1	1.3	4.1		J
perfluorooctanoic acid (PFOA)	8.34	ppt		1	0.70	2.2		
perfluorononanoic acid (PFNA)	[1.88]	ppt		1	1.3	4.1		J
perfluorooctanesulfonic acid (PFOS)	12.6	ppt		1	1.5	4.7		
perfluorodecanoic acid (PFDA)	[1.95]	ppt		1	1.2	3.8		J
perfluoroundecanoic acid (PFUa)	ND	ppt		1	1.2	3.7		
perfluorododecanoic acid (PFDoA)	ND	ppt		1	0.95	3.0		
perfluorotridecanoic acid (PFTriDA)	ND	ppt		1	0.97	3.1		
perfluorotetradecanoic acid (PFTa)	ND	ppt		1	0.88	2.8		
C13-PFHxA (SURR)	85.427%			1				S
C13-PFDA (SURR)	91.791%			1				S

NOTES APPLICABLE TO THIS ANALYSIS:

J = Result enclosed in brackets is between LOD and LOQ, a region of less certain quantitation.
 S = This compound is a surrogate used to evaluate the quality control of a method.

The PFOA branch isotope peak is included in the PFOA calculation per EPA directive.

