



Brunswick County  
Code Administration Department / Fire Marshal's Office  
75 Courthouse Drive NE Building "I"  
P.O. Box 249  
Bolivia, NC 28422  
910.253.2021 Office  
910.253.2024 Fax

## **FIRE WATCH AGREEMENT**

In accordance with the State Fire Code, The Brunswick County Fire Marshal's Office requires a Fire Watch to be conducted any time a fire alarm system or fire protection system is out of service. The entire facility shall be continuously monitored by roving Fire Watch personnel, with areas being observed hourly.

A log shall be kept detailing the date, time and signature of the person conducting the Fire Watch and any abnormal conditions.

### **Fire Watch Duties**

The Brunswick County Fire Marshal's Office or designee may require a building owner to provide a fire watch if a fire protection system fails, if there are an excessive number of accidental activations or nuisance alarms, or a special circumstance or event. Personnel to conduct the fire watch are determined by the building owner.

### **Definition of Fire Watch**

The assignment of a person or persons to an area for the express purpose of notifying the fire department and/or building occupants of an emergency, preventing a fire from occurring, extinguishing small fires, or protecting the public from fire or life safety dangers.

### **Requirements of the NC State Fire Prevention Code**

#### **Fire Alarm and/or Sprinkler System Shutdown**

NFPA 101 – NCSFC Section 901.7- Where a required Fire Protection System is out of service, the fire department and the fire code official shall be notified immediately and, where required by the fire code official, the building shall either be evacuated or an approved fire watch shall be provided for all occupants left unprotected by the shutdown until the fire protection system has been returned to service.

### **Owner Responsibilities**

- a. Establish, instruct and maintain fire watch personnel.
- b. Notify the fire alarm monitoring company.

- c. Notify the Brunswick County 911 Dispatch Center at (910)253-7490 and the Brunswick County Fire Marshal's Office that the system is not working and again when the system is restored. (910) 253-2021 or email [Fire.marshall@brunswickcountync.gov](mailto:Fire.marshall@brunswickcountync.gov)
- d. Contact a licensed and qualified contractor to fix the fire protection system(s).
- e. If a Notice of Violation or Civil Citation has been issued, contact the designated Fire Marshal when the system has been repaired.

**Personnel serving as a fire watch must have the following duties**

- a. Conduct periodic patrols of the entire facility as specified.
- b. Identify any fire, life or property hazards.
- c. Notify the Fire Department if a fire is discovered by calling 911 with the exact address and type of emergency.
- d. Notify occupants of the facility of the need to evacuate. If the sirens or public address function of the alarm system are still functional, use them to assist with evacuation of the building.
- e. Determine at least one means of direct communication with the Fire Department. A telephone or radio is acceptable.
- f. Maintain a log of fire watch activities.
- g. Have knowledge of the location and use of fire protection equipment, such as fire extinguishers.
- h. Fire watch personnel cannot have other duties besides their assigned fire watch. However, the Fire Department may designate other duties.

NOTE: The fire watch will not perform fire-fighting duties beyond the scope of the ordinary citizen.

**Frequency of Inspections**

Fire watch personnel should patrol the entire facility every 15 minutes in the following situations.

- a. The facility has people sleeping
- b. The facility is an institutional occupancy.

The facility is occupied assembly occupancy. Facilities that do not meet the requirements for a 15-minute patrol frequency should have a fire watch patrol every 1 hour/60-minutes.

**Record Keeping**

A fire watch log should be maintained at the facility. The log must be available at all times during the fire watch and should show the following:

1. Address of the facility.
2. Times that the patrol has completed each tour of the facility.

3. Name of the person conducting the fire watch.
4. Record of communication(s) to the fire department and monitoring company.
5. Record of other information as directed by the fire department personnel.

### **Cancellation of Fire Watch**

It is the owners' responsibility to cancel the fire watch once the fire protection system has been fully restored or after the end of the special circumstances or event.

Once the fire watch has been cancelled, the owner or representative must notify the monitoring company, the Local Fire Department and Brunswick County Fire Marshal's Office.





