



ADDENDUM #1  
November 18, 2021

Trailwood Drive Force Main  
Replacement  
Brunswick County Public  
Utilities 250 Grey Water Rd.  
Supply, NC 28462

This Addendum #1 to the Trailwood Drive Force Main Replacement Project forms a part of the Contract Documents and modifies the original Bidding Documents as noted below. Bidders shall acknowledge receipt of this Addendum in the space provided on the Bid Acceptance Form. Bids that do not include documentation of Addendum Receipt may not be considered or reviewed.

REVISED BID DUE DATE AND TIME:

- Included with this Addendum is the revised Bid Due Date and Time.

CONTRACTOR QUESTIONS:

- Included with this Addendum is a list of additional Contractor Questions and Answers and pre bid meeting sign in sheet.

END OF DOCUMENT



**Trailwood Drive Force Main Replacement  
Brunswick County Public Utilities  
250 Grey Water Rd. Supply, NC 28462**

**Bids may be received by email, mail, or hand delivery. All bids must be received by 4:00 p.m. ET on November 23, 2021. Bids must be clearly marked: “Trailwood Drive Force Main Replacement.” Brunswick County will not be responsible for the failure of any mail or delivery service to deliver a bid prior to the stated date and time. Regardless of the manner of submission, any bid received after the stated date and time, or bids not submitted to the correct location or in the designated manner will not be considered. Incomplete bids or bids inconsistent with the required format may be disqualified from consideration.**

Those interested should submit one (1) original fully completed Bid Acceptance Form along with Proof of Insurance and a copy of their General Contractor’s License to:

Email

paul.biagiotti@brunswickcountync.gov

Post Office Delivery

Paul Biagiotti  
Brunswick County Public Utilities  
P. O. Box 249  
Bolivia, NC 28422

Hand Delivery or Alternate Shipping Service

Paul Biagiotti  
Utilities Operations Center  
250 Grey Water Road NE  
Supply, NC 28462

Bidders are responsible for ensuring they have all addenda.



## CONTRACTOR QUESTIONS AND ANSWERS

### Q1

Will the area of the HDD need to be cleared?

### A1

***No. Clearing is to take place up to the tie in points of the HDD, not the section of the HDD itself.***

### Q2

Will silt fence be needed along clearing limits?

### A2

***No. Silt fence will be required at HDD entry and exit points as per plan.***

### Q3

Are DIP fittings to be 401 lined?

### A3

***Yes. All DIP associated with sewer are to be 401 lined.***

### Q4

Does the clearing area need to be cleared and grubbed, or just cleared?

### A4

***The clearing area is to be cleared and grubbed.***

### Q5

Are electronic submittals acceptable rather than paper copies?

### A5

***Yes.***

### Q6

Can the job be more than 50% subcontractor work?

### A6

***Yes.***

### Q7

Can as-builts be provided in 40 scale?

### A7

***Yes.***

### Q8

Can flows be provided on existing force main?

### A8

***No; however, Brunswick County Public Utilities has performed a trial shutdown to include pump and haul operations. This shutdown occurred on 11/18/21 between the hours of 10:30am - 12:30pm.***



*The following equipment was utilized to successfully complete this shutdown:*

- *One (1) 4" Pump set at Trailwood Pump Station to fill trucks*
- *Two (2) 4000-gallon pump trucks*

*Contractor is responsible for providing the necessary equipment and materials to perform a successful shutdown to complete force main tie ins.*

11/9/21 Pre Bid St. James 1:00pm  
Trailwoods Drive FM Replacement

Sign In Sheet

Name	Contact Info	email
Paul BIAENOTT	BEPU	
<del>M. [Signature]</del>	BEPU	
Eddie Mullen	CCI	emullen@carolinacivilworks.com
Jack Woland	SJP POA	jack@stjamespoa.net
Walter J Carmichael	Carmichael Const Co Inc	Walter@Carmichaelcc.com
JOHNATHAN BUIOTT	TA LOVING CO.	JBUIOTT@TALOVING.COM